

New Water Service

Use a saddle tap on the Main. Service line piping should be 1" CTS (Copper Tubing Size HDPE Plastic with Stainless Steel Inserts)

A Tracer wire must be installed from the corporation at the Main all the way to the house. The tracer will shall also run up the curb stop valve box with a piece of the wire sticking up.

All work will be inspected by the Jaffrey Water Department prior to back filling.

The customer is also responsible for providing a clean, dry, above freezing and accessible location for the water meter.

